




# CRAH Retrofit and Energy Savings Project Danny Johnson Director, Technical Operations

Danny Johnson Director, Technical Operations
Silicon Valley Leadership Group - Data Center Efficiency Summit
October 24, 2012

2260 E. El Segundo Boulevard - A Digital Realty Datacenter



### **Project Scope**

- Upgrade CRAH fans for variable speed operation
- Transition from manual to automated/dynamic environment
  - Motor speeds change to meet IT equipment inlet air set points
  - Create cooling buffer and unlock stranded cooling capacity
  - Optimize operational capacity to increase capacity of existing data center infrastructure
- Rack wireless temperature sensors monitor IT equipment inlet air conditions
- Humidity sensors in each Colo room. Power sensors on each CRAH
- Data collection of 1,274 monitored points
- Reduce capacity requirements from over extended grid
- Project Team: Digital Realty, Lawrence Berkley National Labs, So Cal Edison, Vigilent



### **Project Objectives**

- 1 Reduce the part load mechanical demand profile and improve PUE
- Maximize cooling capacity utilizing existing CRAH units
- 3 Delivery graphic demonstration of real-time heat profile
- 4 Develop and implement improved rack management practices with existing customers
- Improve ROI through use of grant award funding (Lawrence Berkeley National Laboratory) and public utility rebate program (Southern California Edison)




### **Project Timeline**

|                             | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct |
|-----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Project Funded              |     |     |     |     |     |     |     |     |     |     |     |
| VFD Installation            |     |     |     |     |     |     |     |     |     |     |     |
| EC Plug Fan<br>Installation |     |     |     |     |     |     |     |     |     |     |     |
| Vigilent System<br>Install  |     |     |     |     |     |     |     |     |     |     |     |
| Vigilent System<br>Go Live  |     |     |     |     |     |     |     |     |     |     |     |



### Closed Loop Wireless Control Diagram





### Plug Fan with EC Motor

#### Plug Fan Installed




Note: Impeller under the floor for better air flow

#### **Plug Fan Upside Down on Pallet**






### CRAH Power Reduction Due to Fan Type Change












#### CRAH Fan Improvement Program Total Infrastructure Power Reduction













## Colo 3 Controls Response (Baseline vs. Auto)








| Colo<br>Control<br>Group | CRAH Type                      | # of<br>CRAHs<br>On/Total | Average<br>Fan<br>Speed | % Energy<br>Savings | Setpoints to meet<br>Customer SLAs<br>(ASHRAE 64.4 – 80.6) |
|--------------------------|--------------------------------|---------------------------|-------------------------|---------------------|--|
| 1                        | Data Aire DACD-3034 30 Ton     | 7/7                       | 100%                    | 0                   | ASHRAE   |
| 2                        | Data Aire DACD-3034 30 Ton     | 8/8                       | 100%                    | 0                   | ASHRAE   |
| 3 & 4                    | Data Aire DACD-3034 30 Ton     | 5/18                      | 40%                     | 88%                 | 64.4-77  |
| 5 & 6                    | Data Aire DACD-3034 30 Ton     | 15/16                     | 89%                     | 25%                 | ASHRAE   |
| 7                        | Data Aire DACD-3034 30 Ton     | 3/9                       | 49%                     | 88%                 | ASHRAE   |
| 9 & 10                   | Liebert FH740C-AA005291 50 Ton | 10/14                     | 72%                     | 61%                 | ASHRAE   |
| Total                    |                                | 48/72                     |                         | 38%                 |  |




#### CRAH Fan Improvement Program Total Site Savings Estimate





#### Over-Cooled

#### **Optimized Cooling**







Source: Vigilent

### Before Blanking Plates

### After Blanking Plates







Source: Vigilent

#### Conclusion

- Plug Fans with VFD's and the Plug Fans with Electrically Commentated motors actually saved approximately 230 kW of demand
- Vigilent Controls running in Automatic control saved 85+ kW of demand for a total of to 290 kW of demand reduction on the mechanical load with no reduction of the IT load
- Pier Grant and Utility rebate resulted in a return on the investment period of less than 12 months
- Colo 1 & 2 customers now adding blanking plates to racks which when complete will provide additional energy savings. electric loads gained and cooling capacity buffer gained
- Ability to see heat profiles room to room and in different areas of the room in real time exceeded expectations
- Digital Realty saving 2.9 M kWh per year since the completion of this project, providing an annual greenhouse gas emission reduction of 1.9 million pounds of carbon dioxide (CO<sub>2</sub>).





**Data Center Solutions**